

SCS Global Services does hereby certify that an independent assessment has been conducted on behalf of:

Franklin International

2020 Bruck Street, Columbus, OH

For the following product(s):

Flooring Adhesives:

Flash Cove, Franklin 920, Titebond 571, Titebond 771, Titebond 801, Titebond 811, Titebond 821

This product meets all of the necessary qualifications to be certified for the following claim:

FloorScore® Adhesives

Indoor Air Quality Certified to SCS-EC10.3-2014

Conforms to the CDPH/EHLB Standard Method v1.1-2010 (effective January 1, 2012) for the school classroom, private office, and single-family residence parameters when modeled as Flooring. Also, conforms to the SCAQMD Rule 1168 - Adhesive and Sealants (January 2005); Hong Kong Air Pollution Control (VOC) Regulation.

Average Product Application Amount: 1018 g/m²

Measured Concentration of Total Volatile Organic Compounds (TVOC): Between 0.5 – 5.0 mg/m³ (in compliance with CDPH/EHLB Standard Method v1.1-2010)

Methylene Chloride and Perchloroethylene are not intentionally added to certified products.

Registration # SCS-FS-03185

Valid from: January 1, 2015 to September 30, 2015

SCS Global Services is currently the only certification body approved by the Resilient Floor Covering Institute (RFCI) to provide FloorScore® product certification; certified products are only listed on the SCS Green Products Guide, <http://www.scsglobalservices.com/certified-green-products-guide>.



ANSI ACCREDITED PROGRAM
PRODUCT CERTIFICATION
#0821



A handwritten signature in blue ink that reads "Robert J. Hrubes".

Robert J. Hrubes, Ph.D., Executive Vice President
SCS Global Services
2000 Powell Street, Ste. 600, Emeryville, CA 94608 USA